

OFFICE OF THE STATION OFFICER

FIRE STATION KADAMTALA

Dated - 27th Sept-2018

To,
The Head Master
Govt. Secondary School Uttara
Middle Andaman.

Sub: Inspection report of first aid fire fighting equipments reqs

Sir,
Kindly refer letter no. F.NO. 4-38/GSSS/KT/OM/PRI/2018/299. It is to inform that the building of G.S.S. Uttara has been inspected from fire safety point of view and the details of first aid fire fighting equipments are as under:-

Existing: Primary block

- Ⓐ DCP extn. = 01 no. U/S
- Ⓑ CO₂ extn. = 01 no. U/S
- Ⓒ Water CO₂ extn. = 01 no. U/S
- Ⓓ Fire bucket - 01 no. Damage.
- Ⓐ Water CO₂ extn. (09 liter) = 2 nos (with refill)
- Ⓑ CO₂ extn. (4.5 kg) = 1 no.
- Ⓒ DCP extn. (6kg) = 1 no. (with refill)
- Ⓓ Fire bucket 03 nos with stand (filled with sand & water)

Recommendation:

Existing: Middle block

- Ⓐ DCP extn. = 01 no. U/S
- Ⓑ CO₂ extn. = 01 no. U/S
- Ⓒ Water CO₂ extn. = 01 no. U/S

Recommendation:-

- Ⓐ Water CO₂ extn. (09 liter cap) = 02 nos (with refill)
- Ⓑ CO₂ extn. (4.5 kg cap) = 01 no.
- Ⓒ DCP extn. (6kg cap) = 01 no. (with refill)
- Ⓓ Fire bucket 03 nos with stand (filled with sand & water)

Existing Middle block Second part = Nil

Recommendation:-

- Ⓐ Water CO₂ extn. (09 liter) = 01 no. (with refill)
- Ⓑ CO₂ extn. (4.5 kg) = 01 no.
- Ⓒ DCP extn. (6kg) = 01 no. (with refill)

L.C.C. Double Story new Building

Ground floor - Existing: Nil

Recommendation:-

- (A) Water CO₂ extn. (9 litre) = 2 nos (with refill)
- (B) CO₂ extn. (4.5 kg) = 2 nos.
- (C) DCP extn. (6 kg) = 2 nos (with refill)
- (D) Fire bucket 04 nos. with stand (filled with sand & water)

(First floor) Existing: Nil.

Recommendation:-

- (A) Water CO₂ extn. (9 litre) = 02 nos (with refill)
- (B) CO₂ extn. (4.5 kg) = 02 nos
- (C) DCP extn. (6 kg) = 02 nos.

Mid day meal Shed: Existing = Nil.

Recommendation:-

- (A) Water CO₂ extn. (9 litre) = 01 no (with refill)
- (B) Mechanical foam extn. (9 litre) = 01 no. (with refill)
- (C) CO₂ extn. (2 kg) = 01 no.
- (D) Fire bucket 02 nos with stand (filled with sand & water)

Note:- (1) Staffs should be trained in operation of fire extinguishers & evacuation procedures from the near by fire station as an when required.

(2) The above mentioned all the extinguishers conforming IS-15683:2006 with squeeze grip is to be provided.

(3) All equipments should be avoided from sunlight & rain.

(4) In addition to the above 03 nos refills of water CO₂ extinguisher, 03 nos refills of DCP extinguisher & 01 no refills of Mechanical foam extinguishers are also recommended for the further use, i.e for refilling & demonstration purpose.

copy to:

(A) HB (Rgt) for kind information please.

Office Initials to send the report to
DDO, 01566, Kitala.

J E T
1/c FLS Kitala
Station Officer-in-Charge
New Station, Kitala