



नि.अ. (कार निकोबार) / IFB (Car Nicobar)
आर.डी. सं. / R.D. No. 1157
दिनांक / Date 14/5/24

No -
OFFICE OF THE INSPECTOR FIRE BRIGADE
CAMPBELL-BAY, GREAT NICOBAR
Nicobar District

To,
The Principal,
PM SHRI Govt. Sr. Secondary School,
Campbell Bay .

Campbell-Bay , Dated 14th May 2024.

Sub:- Fire Safety Audit- Requirement of Fire Safety & Fire Protection-
Prevention measures at PMSHRI Govt. Sr. Secondary School, Campbell
Bay - reg

Sir,

Please refer on the subject cited above. Gist of the status of existing fire safety arrangements and Requirement of Fire Safety & Fire Protection-
Prevention measures at PMSHRI Govt. Sr. Secondary School, Campbell Bay
as per NBC Part IV 'Fire and Life safety' are further furnished below under
mandatory safety precaution to be observed as per DGCD, MHA vide letter
no VIII-11011/6/2004-DGCD(F), dated 30/07/2004, for issuance of FCC to
school -

A. FIRE PREVENTION AND FIRE PROTECTION ARRANGEMENTS -

| Sl No | Name of Fire Extinguishers | Qty. | | Recommended |
|-------|--------------------------------|-------|--|--------------------------|
| | | Exist | Status | |
| 1. | CO2 (4.5Kg) | 20 | 10-OK | 10 -Nos need Replacement |
| 2. | DCP (6Kg) | 14 | 03 Nos (05 kg) are old and out dated. Require replacement. | All Need Refilling |
| 3. | WATER-CO2(9ltr) | 09 | 03- Empty | All Need Refilling |
| 4. | Mechanical Foam(AFFF) (09ltrs) | 02 | - | All need Re-filling |
| 5. | Fire Buckets Stand | 03 | OK | - |
| 6. | Fire Buckets | 11 | 04- U/S | 04-Need replacement |