

NO.FS/SHDP/286
OFFICE OF THE STATION OFFICER
FIRE STATION SHAHEED DWEEP

Dated-28/03/2024

To,
The Principal
Govt. Senior Secondary School
Laxmanpur-I
Shaheed Dweep

Sub:- Fire Safety audit report of Govt. Senior Secondary School Shaheed Dweep -reg.

Sir,

This is to inform that Govt. Senior Secondary School, Shaheed Dweep has been inspected from fire safety point of view and the status of existing fire fighting equipments and further recommendations are furnished below.

SL. NO.	NAME OF FIRE FIGHTING EQUIPMENTS	EXISTING	STATUS/REMARKS	RECOMMENDATION
Block -A Administrative building (RCC double storied building) 08 Nos. Rooms (Office, Exam cell, Computer Lab etc.)				
1.	Co ₂ Extinguisher 4.5 kg	03 Nos.	Needs HPT & replacement of discharge tube	--
2.	ABC Powder Extinguisher 6 kg	--	--	02 No. As per IS 15683
Block -B (RCC double storied building) 05 Nos. Class Rooms including 01 No. Staff Room				
1.	Co ₂ Extinguisher 4.5 kg	05 Nos.	Needs HPT & replacement of discharge tube	--
2.	ABC Powder Extinguisher 6 kg	--	--	02 No. As per IS 15683
Block -C (RCC double storied building) 16 Nos. Class Rooms including Library & Laboratory				
1.	Co ₂ Extinguisher 4.5 kg	09 Nos.	Needs HPT & replacement of discharge tube	--
2.	ABC Powder Extinguisher 6 kg	--	--	04 No. As per IS 15683
Block -D (Semi RCC single storied building) 03 Nos. Class Rooms				
1.	Co ₂ Extinguisher 4.5 kg	03 Nos.	Needs HPT & replacement of discharge tube	--
2.	ABC Powder Extinguisher 6 kg	--	--	01 No. As per IS 15683


Further,

1. The teaching, non-teaching staffs and students should be trained in operation and maintenance of firefighting equipments.
2. Fire drill involving school teams and students to be conducted once in 06 months.
3. Records regarding conduct of mock drill to be maintained.

4. The store rooms ,office rooms ,library and laboratory section should be well maintained without any scope for fire accident due to any cause including electrical origin.
5. Each block also should have an evacuation plan along with instruction to be followed at the time of fire incident.
6. Exit signs boards in green color to be displayed at all escape routes and staircase till the assembly point.
7. All fire fighting equipments should be safe guarded from direct sun light and rain.
8. Recommended 06 Nos. Fire Bucket with stand as per IS 2546.

It is requested that the above recommended fire fighting equipments may be procured and installed at the earliest and intimate to the undersign for re-inspection.

Yours faithfully



In-charge

FS Shaheed Dweep

Copy to-

- 1) Inspector Fire Brigade, Swaraj Dweep.

NO.FS/SHDP/
OFFICE OF THE STATION OFFICER
FIRE STATION SHAHEED DWEEP

Dated-01/08/2024

To,
The Incharge
Patwari Office
Shaheed Dweep

Sub:- Fire Safety audit of Patwari office Shaheed Dweep -reg.

Sir,
This is to inform that the Patwari Office, Shaheed Dweep was inspected from fire safety point of view and the following shortcomings and recommendations are furnished below.


SL. NO.	NAME OF FIRE FIGHTING EQUIPMENTS	RECOMMENDATION
1.	Co ₂ Extinguisher (4.5 kg)	01 Nos.
2.	ABC Extinguisher (06 kg)	02 Nos.
3.	Fire bucket with stand	04 Nos.

Further,

- 1) All the fire extinguisher should be installed at a conspicuous place and at a height not more than 1.5 mtrs. From the ground level.
- 2) All fire safety equipment should be safe grounded from direct sunlight and rain.
- 3) A proper record in a register regarding the maintenance of the extinguishers to be maintained.
- 4) All staffs should be conversant with the operation, refilling & maintenance of fire extinguishers.
- 5) No any loose wiring to be allowed, if found the same to be rectified by intimating concerned department. All steps may be taken to prevent fire due to short circuit.
- 6) Emergency telephone numbers to be displayed at conspicuous place.

It is requested that the above recommended fire safety arrangements may kindly be fulfilled immediately and compliance may be communicate to this office at the earliest.

Yours faithfully


In-charge
Fire Station
Shaheed Dweep

Received
S. S. S.
02/08/24
R(B)

Copy to
1) The Dy. SP (F&ES) Port Blair for king information
2) Inspector Fire Brigade, Swaraj Dweep.