

No.5-193/2024/18/IFB(HQ)/219

निरीक्षक अग्निशमन का कार्यालय

OFFICE OF THE INSPECTOR FIRE BRIGADE

अग्निशमन तथा आपातकालीन सेवा मुख्यालय

FIRE AND EMERGENCY SERVICE HEAD QUARTER

\*\*\*\*\*

पोर्टब्लेयर/Port Blair, दिनांक/dated 13<sup>th</sup> July, 2024

To,

The Principal  
Govt. Sr. Sec. School  
Tushnabad

**Sub:** - Fire Safety audit of Schools - reg.

Sir,

With reference to your letter No. 1-31/GSSS/TB/2024/153 dated 24/04/2024 on the subject cited above the schools under your jurisdiction were inspected by Fire Brigade Officer (I/C FS Ferrargunj) from fire safety point of view and the fire & life safety requirements are furnished below:

**I. GSSS TUSHNABAD**

Sl. No.	Name of equipment	Existing	Status of existing eqpt. & further Recommendation
<b>G+1</b>			
<b>Ground Floor:-</b> Smart Class Room, CIC Lab, ICT Lab, Vocational Lab(IT), Library, Games room, Science Lab, Girls comfort & care room) Staffs room.			
1.	Water Co2 (09 Ltr.) (2011)	01	Unserviceable to be removed
2.	Foam (09 Ltrs.) (2011)	01	
3.	Co2 (4.5 Kg) (2011)	02	Life span will expire in 2026. 02 Nos new CO2 to be procured
4.	ABC Powder (6 kg)	Nil	01
5.	Water type Fire (09 ltr.) (2019)		Hydraulic Pressure Test (HPT) & refilling to be done.
6.	Fire bucket with stand	08	To be filled with dry loose sand
7.	Manual Call Point	Nil	01
8.	Hose reel	Nil	To be provided as per norms
9.	Fire evacuation plan	Nil	01 No. To be displayed
<b>First Floor:-</b> 06 Class room, Principal room & office room			
1.	Water Co2 (09 Ltr.) (2011)	01	Unserviceable to be removed
2.	ABC Powder (6 kg)	Nil	01
3.	Co2 (4.5 Kg) (2011)	02	Life span will expire in 2026. 02 Nos new CO2 to be procured
4.	Water type Fire (09 ltr.) (2019)	01	Hydraulic Pressure Test (HPT) & refilling to be done.
5.	Manual Call Point	Nil	01
6.	Hose reel	Nil	To be provided as per norms
7.	Fire evacuation plan		01 No. To be displayed
8.	01 No. additional staircase of 1.50 mtr. Width to be provided.		