

CENTRAL WATER LABORATORY

ANDAMAN NICOBAR STATE WATER AND SANITATION MISSION.
CE's Office Complex, APWD, Nirman Bhawan, Port Blair

TEST REPORT

Test Report/Job Card No. 2210004

Date: 06/10/2022

CUSTOMER DETAILS

Customer Name & Address	The Principal GSSS (Telugu), Haddo.
Customer Reference	Letter No. 7-13/GSSS/HH/TEL/SMSA/2022-23/111 dated 06/10/2022

SAMPLE DETAILS

Product Category	Water	Sample Code	2210004
Sample Name	Water	Sample Received on	06/10/2022
Sample Conditions at Receipt	Fit for Analysis	Test Commenced on	06/10/2022
Sample Quantity & Packing	2 L in Plastic Bottle	Test Completed on	07/10/2022
Information Provided by Customer	Name of Source: Drinking Water		

TEST RESULTS - CHEMICAL

Sl. No.	PARAMETERS	TEST METHOD	UNIT	RESULT	Requirement as per IS 10500:2012	
					Acceptable Limit	Permissible limit in the absence of alternative
1	pH @ 25 °C	IS 3025 (P11):2022		7.68	6.5 - 8.5	
2	Turbidity	IS 3025 (P10):1984	NTU	6.80	Max: 1	
3	Residual Chlorine	IS 3025 (P26):2021	mg/L	Nil	Min: 0.2	
4	Total Hardness as CaCO ₃	IS 3025 (P21):2009	mg/L	50.5	Max: 500	
5	Calcium as Ca	IS 3025 (P40):1991	mg/L	10.58	Max: 75	
6	Magnesium as Mg	IS 3025 (P46):1994	mg/L	8.83	Max: 30	
7	Total Alkalinity as CaCO ₃	IS 3025 (P23):1986	mg/L	48	Max: 500	
8	Chloride as Cl	IS 3025 (P32):1988	mg/L	8.93	Max: 250	
9	Total Dissolved Solids	IS 3025 (P16):1984	mg/L	113	Max: 500	

Note: Sample is submitted by customer and the results apply to the sample as received.
Remarks:

End of Report

Inference
Data entry operator
AKSWSM/FRM/7.8/01/01-00

[Signature]
Quality manager