



अंडमान तथा निकोबार प्रशासन
Andaman and Nicobar Administration
खाद्य सुरक्षा विभाग
Department of Food Safety
चलन्त खाद्य प्रयोगशाला
Mobile Food Testing Laboratory

Port Blair dated the 26/7/2024

Test Result of Food Sample (Informal)
खाद्य नमूना का परीक्षण (अनौपचारिक)

Date of Receipt: 25.07.2024

Sample No: MFTL/2024/214

Nature of sample: Tank Water


Sample Received from: N. Rekha (FSO)
Gr. SSS (School) Delanipur

Fee Received: NIL

Receipt Details: NIL

Test Started at: 27.07.2024

SL No	Parameter Tested	Test Result	Permissible Range
1.	Physical appearance	Normal	Normal
2.	PH	7.5	6.5 - 8.5
3.	Total dissolve solid	24	Upto 500gm/Litre
4.	Turbidity	0.7	2 NTU
5.	Conductivity	51	Upto 800 μ s/CM
6.	Odour	Agreeable	Agreeable
7.	Taste	Agreeable	Agreeable
8.			


Sr. Lab Technician
(State Food Lab)

Report no: MFTL/2024/214
Note: This report is only for surveillance purpose.

तकनीकी अधिकारी
Technical Officer
चलन्त खाद्य परीक्षण प्रयोगशाला
Mobile Food Testing Laboratory
अ. तथा नि. द्वीप समूह, पोर्ट ब्लेयर
A & N Islands, Port Blair.

Forwarded to Sr. Sir
CBSE J/c

Rm
01/08/2024



अंडमान तथा निकोबार प्रशासन
Andaman and Nicobar Administration
खाद्य सुरक्षा विभाग
Department of Food Safety
चलन्त खाद्य परीक्षण प्रयोगशाला
Mobile Food Testing Laboratory

Port Blair dated the 26.07.2024

Test Result of Food Sample (Informal)
खाद्य नमूना का परीक्षण (अनौपचारिक)

Date of Receipt: 25.07.2024

Sample No: MFIL/2024/215

Nature of sample: RO Water

Sample Received from: N. Rekhwal (FSO)
Gr. 555 (School) Delanipur

Fee Received: NIL

Receipt Details: NIL

Test Started at: 26.07.2024

SL No	Parameter Tested	Test Result	Permissible Range
1.	Physical appearance	Normal	Normal
2.	PH	7.2	6.5 - 8.5
3.	Total dissolve solid	19	Upto 500gm/Litre
4.	Turbidity	0.6	2 NTU
5.	Conductivity	38	Upto 800 μ s/CM
6.	Odour	Agreeable	Agreeable
7.	Taste	Agreeable	Agreeable
8.			

Report no: MFIL/2024/215

Note: This report is only for surveillance purpose.

Forwarded to Shri Siva S.
GIT (maths)
CBSE I/c
P
01/08/2024

St. Lab Technician
(Mobile Food Lab)
Technical Officer

चलन्त खाद्य परीक्षण प्रयोगशाला
Mobile Food Testing Laboratory
अ. तथा नि. द्वीप समूह, पोर्ट ब्लेयर
A & N Islands, Port Blair.